

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Taylor Coastal Water & Sewer District Chemical Monitoring Public Notice

What happened?

Our water system did not meet the requirements of a drinking water rule. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the 2025 monitoring period, we monitored or tested for Stage 2 Disinfection Byproducts (S2 DBPs), including Total Trihalomethanes (TTHMs) and Haloacetic Acids (HAA5s), outside of our required monitoring period and therefore cannot be sure of the quality of your drinking water at that time. Sampling resumed on September 3, 2025, and the analytical results were within acceptable ranges.

What should I do?

Some people who drink water containing TTHMs in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

Some people who drink water containing HAA5s in excess of the MCL over many years may have an increased risk of getting cancer.

Any customers who are concerned about their exposure to these contaminants can choose alternative sources of water for ingestion.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately.

What is being done?

We have implemented corrective measures to ensure this does not occur again. A comprehensive compliance calendar has been developed that includes all required samples, along with their respective due dates and reporting frequencies. In addition, recurring calendar reminders and notifications have been established for both the Operator and the District Manager to provide advance notice of upcoming deadlines.

For more information, please contact Courtney Valentine 850-295-2950 or contact the Department of Environmental Protection, Potable Water Section at 904-256-1700.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by our water system: **Taylor Coastal Water & Sewer District**
Potable Water System ID: **2624165**
Date distributed: 03/04/2026